



Capacitive Voltage Detecting/Indicating System

Products

VDS/VIS (Voltage detection/indicating System). According to IEC61243-5



Separate HR based system in accordance with the **norm IEC61243-5**, described as VDS and VIS



Phase comparator according to **Norm IEC61243-5**



Indicator VIM 1(single phase)



Indicator VIM 3 (tree phase)

VPIS (Voltage presence Indicating System). According to IEC61958



Indicating element.

HR based system for voltage indication and contacts for simplified phase comparison. in the same module. The unit can be replaced with the switchgear energised. LED indication.



Matching element.

Together with the capacitor in the coupling electrode (C1) and cable length the matching element is matching the different voltage level.



Phase comparator for VPIS

MAXETA

P.O.box 177 Sentrum 3701 Skien
Tlf. + 47 35 91 40 00
Fax. + 47 35 91 40 10
maxeta@maxeta.no - www.maxeta.no